

DECLARATION OF PERFORMANCE

No. DoP-MULTISKY-23

1. Unique identification code of the product-type:

MULTISKY 2023

Natural smoke and heat exhaust ventilator.

2. Intended use:"

Fire Safety

3. Manufacturer:

Powrmatic,

Hort Bridge, Ilminster, Somerset, TA19 9PS, UK

4. System/s of AVCP:

AVCP System 1

5. Harmonised standard:

EN12101:2003

NB 1368

Notified body:

I.F.I. Institut für Industrieaerodynamik GmbH

6. Declared performance/s:

Essential characteristics	Performance	Harmonised technical specification
Nominal activation condition	300°C.	EN12101:2003
Reaction to Fire	Aluminium Blades Class A Polycarbonate Blades Class B	_
Resistance to Heat	B 300	
Ability to Open in Environmental Conditions	Snow Load SL125 Wind Load WL 1500 Low Ambient Temp 0°C	
Response Time	Passed <60s	
Operational Reliability	RE1000	
Aerodynamic Free Area / Effectiveness of hot gas extraction	0.3 – 3.81m ²	

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Lee Herbert

on 25/9/23.

Engineering Manager