

DECLARATION OF PERFORMANCE

No. DoP-ULTRASKY-18

1. Unique identification code of the product-type: **ULTRASKY 2018**
Natural smoke and heat exhaust ventilator.
2. Intended use: **Fire Safety**
3. Manufacturer: **Powrmatic,**
Hort Bridge, Ilminster,
Somerset, TA19 9PS, UK
4. System/s of AVCP: **AVCP System 1**
5. Harmonised standard: **EN12101:2003**
- Notified body: **NB 0757 ift Rosenheim GmbH**
6. Declared performance/s:

Essential characteristics	Performance	Harmonised technical specification
Nominal activation condition	Electrical Signal from remote source.	EN12101:2003
Reaction to Fire	Class E	
Resistance to Heat	B 300	
Ability to Open in Environmental Conditions	Snow Load SL125 Wind Load WL 2000	
Response Time	Passed <60s	
Operational Reliability	RE1000	
Aerodynamic Free Area / Effectiveness of hot gas extraction	0.3 – 3.81m ²	

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:


Lee Herbert on 30/11/21
Engineering Manager